

CERTIFICATE



No. 0P260303.ZYTU060

Test Report / Technical Construction File no. TLZJ26022782761, TEZJ26022782762

Certificate's
Holder:

ZHEJIANG YIDEK TECHNOLOGY CO., LTD.
4F, No. 397, Binhai 21st Road, Xinghai Street, Wenzhouwan New
District, Wenzhou City, Zhejiang Province

Certification
ECM Mark



Product:

Series reactor

Model(s):

CKSG

Adaptive capacitor capacity: 5kvar~50kvar;

Adaptive capacitor voltage: 480V; 50Hz;

Rated inductance: 10.268mH~1.027mH;

Reactance rate: 7%;

Insulation level: H level;

Rated current: 6A~60.1A; Indoor type

Verification to:

Standard:

EN IEC 61558-1:2019, EN 61558-2-20:2011,

EN IEC 61000-6-2:2019, EN IEC 61000-6-4:2019

related to CE Directive(s):

2014/35/EU (Low Voltage)

2014/30/EU (Electromagnetic Compatibility)

Remark:

The manufacturer has voluntarily decided to submit its documents concerning the above-mentioned product for verification. Ente Certificazione Macchine confirms that the documentation made available and immediately returned to it, as containing sensitive data, meets the essential requirements of the above-mentioned directive/standard. The verification activity carried out exclusively concerned the technical documentation and no verification was carried out on the product. This document cannot replace the EC Declaration of Conformity. This document was issued in accordance with regulation RGVOL01 published on the website of www.entecerma.it and concerning voluntary certifications with a non-notified procedure.

Issuance date: 03 March 2026

Expiry date: 02 March 2031

For online check:



Approver
Ente Certificazione Macchine
Legal Representative
Luca Bedonni



Ente Certificazione Macchine Srl

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY
☎ +39 051 6705141 ☎ +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it